

ZUHAIR FAYEZ PARTNERSHIP  CONSULTANT	MINISTRY OF DEFENSE  CLIENT	MASAH CONTRACTING CO.  CONTRACTOR
--	---	---

MATERIAL SUBMITTAL
PROJECT NAME: SUPPORTING BUILDINGS PROJECT (PHASE-2) ZONE-B

SUBJECT: Technical Details for (RED SEA CABLES Factory Co. - RESCAB - LOW VOLTAGE CABLES WITH SAMPLE BOARD)

Specs. Code & Ref.	B.O.Q. Code Ref.	Submittal No. Q5-PH2-ZB-E-MT-002A
		Date Received: 27/01/2020
		Date Returned: _____

Sub-contractor
 Name: **MASAH CONTRACTING CO.** Address: **P.O. Box 272000 Riyadh 11352, Kingdom of Saudi Arabia**
 Address: _____ Phone: **966 55 500 3427** Telex: **+966 011 216 7854**

Manufacturer		Supplier/Agent	
Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)
Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421
Phone: 011-288 6303	Phone: 011-288 6303	Phone: 011-288 6303	Phone: 011-288 6303
Fax: 011-288 6302	Telex: _____	Fax: 011-288 6302	Telex: _____

Information submitted and attached:

Certificates <input type="checkbox"/>	Operation & Maintenance Manual <input type="checkbox"/>
Technical Brochure <input checked="" type="checkbox"/>	Spare Parts List <input type="checkbox"/>
Manufacturer's Data & Specs. <input type="checkbox"/>	As Built Drawings <input type="checkbox"/>
Shop Drawings <input type="checkbox"/>	Warranty <input type="checkbox"/>
Samples <input checked="" type="checkbox"/>	Others (specify) _____

Contractor's Comments:

Pre-qualification of Supplier approved under Document Submittal No. **Q5-PH2-ZB-E-DC-002**

See Attachment 

Note: This review does not relieve the contractor (Contractor)
 Of his responsibilities under the terms of the contract Signature :
 nor authorize additional compensation. Date : **28/01/2020**

Consultant's Comments:





*** THE MANUFACTURER/SUPPLIER DETAILS IS TECHNICALLY ACCEPTABLE AND RECOMMENDED FOR CLIENT APPROVAL.**
*** SAMPLE CABLE SIZES IS ONLY APPROVED AS STANDARD SIZE.**
*** ACTUAL CABLE ON SITE WILL BE AS PER APPROVED SLD.**
 See Attachment

Status:	Discipline	Sign & Date	Resident Engineer	Client Note
A - Approved <input type="checkbox"/>	<input type="checkbox"/> Arch			
B - Approved as noted <input checked="" type="checkbox"/>	<input type="checkbox"/> Civil		Sign :	Sign:
C - Revise and submit <input type="checkbox"/>	<input type="checkbox"/> Mech		Date :	Date:
D - Rejected <input type="checkbox"/>	<input checked="" type="checkbox"/> Elect	<i>Approved 20-01-2020</i>	Name:	Name:
E - Noted/ NA <input type="checkbox"/>	<input type="checkbox"/> HVAC			
	<input type="checkbox"/> LS			

NOTE:- TECHNICAL SUBMITTAL SHOULD HAVE PROPER PRESENTATION.

Remarks:

- The drawings and materials submitted by the contractor should be covered by the contract value. Any additional materials or drawings should be mentioned in the submittal.
- Copies and Attachments: Original (For Consultant), Copy No. (1) (For Consultant), Copy No. (2) (For Site Manager).

ZUHAIR FAYEZ PARTNERSHIP  CONSULTANT	MINISTRY OF DEFENCE  CLIENT	POLY TECHNOLOGIES INC  MAIN CONTRACTOR	MASAH Contracting Co.  SUB CONTRACTOR
---	--	--	--

MATERIAL SUBMITTAL DETAILS

PROJECT NAME : SUPPORTING BUILDINGS PROJECT (PHASE-2) ZOBE-B

Submittal No. : **Q5-PH2-ZB-E-MT-002A**

1	BARE COPPER STRANDED CONDUCTOR	$1 \times 35 \text{ mm}^2, 1 \times 50 \text{ mm}^2, 1 \times 70 \text{ mm}^2$ $1 \times 95 \text{ mm}^2$ Size : 2.5 mm ² to 150 mm ²
2	COPPER / PVC EARTHING CABLE	$1 \times 50 \text{ mm}^2, 70 \text{ mm}^2, 90 \text{ mm}^2, 150 \text{ mm}^2$ Size : 2.5 mm ² to 150 mm ²
3	COPPER XLPE/PVC/UNARMoured LOW VOLTAGE CABLES	Size 4x1.5 mm ² to 4x300 mm ²
		$4 \times 35 \text{ mm}^2, 4 \times 70 \text{ mm}^2$ $1 \times 630 \text{ mm}^2, 4 \times 240 \text{ mm}^2$
	# THE MENTION SIZES OF CABLE IS AS PER SUBMITTED CABLE SAMPLE BOARD	

Reviewer Company Name : **ZUHAIR FAYEZ PARTNERSHIP**

Main Reviewer Name : _____ Designation : _____ Signature : _____ Date _____

Reviewer Name : _____ Designation : _____ Signature : _____ Date _____

Remarks :

- The Drawings and materials submitted by the contractor should be covered by the value. Any additional or drawings should be mentioned in the submittal
- Copies and Attachments : Original (for Consultant), Copy No. (1) (for Consultant), Copy No. (2) (for Site Manager)

 ZUHAIR FAYEZ PARTNERSHIP CONSULTANT	 MINISTRY OF DEFENSE CLIENT	 MASAH CONTRACTING CO. CONTRACTOR
--	---	---

MATERIAL SUBMITTAL
PROJECT NAME: SUPPORTING BUILDINGS PROJECT (PHASE-2) ZONE-B

SUBJECT: Technical Details for (RED SEA CABLES Factory Co. - RESCAB - MEDIUM VOLTAGE CABLES with SAMPLE BOARD)

Specs. Code & Ref.	B.O.Q. Code Ref.	Submittal No. Q5-PH2-ZB-E-MT-003A
		Date Received: 27/01/2020
		Date Returned: _____

Sub-contractor
 Name: **MASAH CONTRACTING CO.** Address: **P.O. Box 272000 Riyadh 11352, Kingdom of Saudi Arabia**
 Address: _____ Phone: **966 55 500 3427** Telex: **+966 011 216 7854**

Manufacturer		Supplier/Agent	
Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)	Name: RED SEA CABLES FACTORY CO. (RESCAB)
Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421	Address: PO BOX 859, RIYADH 11421
Phone: 011-288 6303	Phone: 011-288 6303	Phone: 011-288 6303	Phone: 011-288 6303
Fax: 011-288 6302	Telex: _____	Fax: 011-288 6302	Telex: _____

Information submitted and attached:

Certificates <input type="checkbox"/>	Operation & Maintenance Manual <input type="checkbox"/>
Technical Brochure <input checked="" type="checkbox"/>	Spare Parts List <input type="checkbox"/>
Manufacturer's Data & Specs. <input type="checkbox"/>	As Built Drawings <input type="checkbox"/>
Shop Drawings <input type="checkbox"/>	Warranty <input type="checkbox"/>
Samples <input checked="" type="checkbox"/>	Others (specify) <input type="checkbox"/>

Contractor's Comments:



Pre-qualification of Supplier approved under Document Submittal No. Q5-PH2-ZB-E-DC-002

See Attachment 

Note: This review does not relieve the contractor (Contractor)
 Of his responsibilities under the terms of the contract Signature :
 nor authorize additional compensation. Date : **27/01/2020**

Consultant's Comments: **# 3x185mm² CU/XLPE/STA/PVC + 3x300mm² CU/XLPE/STA/PVC**

THE MANUFACTURER/SUPPLIER SUBMITTED DETAILS IS ACCEPTABLE AND RECOMMENDED FOR CLIENT'S APPROVAL.
SAMPLE CABLE SIZE IS APPROVED AS STANDARD SIZE ONLY.
ACTUAL CABLE SIZE ON SITE WILL BE AS PER APPROVED POWER SLD.

Status:	Discipline	Sign & Date	Resident Engineer	Client Note
A - Approved <input type="checkbox"/>	<input type="checkbox"/> Arch			
B) Approved as noted <input checked="" type="checkbox"/>	<input type="checkbox"/> Civil		Sign : _____	Sign : 
C Revise and submit <input type="checkbox"/>	<input type="checkbox"/> Mech		Date : _____	Date : _____
D - Rejected <input type="checkbox"/>	<input checked="" type="checkbox"/> Elect	 30-01-2020	Name : _____	Name : _____
E - Noted/ NA <input type="checkbox"/>	<input type="checkbox"/> HVAC			
	<input type="checkbox"/> LS			

NOTE:- TECHNICAL SUBMITTAL SHOULD HAVE PROPER PRESENTATION.

Remarks:

- The drawings and materials submitted by the contractor should be covered by the contract value. Any additional materials or drawings should be mentioned in the submittal.
- Copies and Attachments: Original (For Consultant), Copy No. (1) (For Consultant), Copy No. (2) (For Site Manager).