



NUMBER Y02-03-00-06/01  
DATE OF ISSUE 01/04/1435



HAWAZEN AL JAZIRA FOR CONTRACTING  
P.O. Box 242200, Riyadh, Saudi Arabia


Contract Title : **CONSTRUCTION OF ROAD 3 BETWEEN ROAD NO. 4 AND 12**  
Contract No. **JCPDI R-3004**

**SUBMITTAL FOR**

<input type="checkbox"/> Shop Drawing	<input checked="" type="checkbox"/> Materials	<input type="checkbox"/> Others	Date	23-Sep-20
<input checked="" type="checkbox"/> Approval	<input type="checkbox"/> Verification	<input type="checkbox"/> Information	Contractor Submittal No	HAI-RCJ-SUB-JCPDI-R-3004-0032.R1
<input type="checkbox"/> Record	<input type="checkbox"/> Deviation	<input type="checkbox"/> Others	EWR / CSG No.	
ATTENTION : <b>Engr. Konstantinos Aidinis</b> RC Authorized Representative			Previous CSG / EMR Log	
<input type="checkbox"/> First Submittal	<input checked="" type="checkbox"/> Re Submittal	<input type="checkbox"/> Previous Sub No.		

Subject Reference Specs: \_\_\_\_\_  
Description / Subject: **Medium & Low Voltage Cables (Rescab)**

- Number of Attachment
- 1 Action to CSG comments
  - 2 EWR List
  - 3 Hard copy - (2 sets)
  - 4 Soft copy in CD



Contractor Certification " Having checked this submittal we certified that it conforms to the requirement of the Contract Document in all respect except otherwise indicate herein"  
Check by: QA/QC Engineer Signed by Project Manager

**Royal Commission Review / Construction support Group**

AR  CE  EE  ME  SE  OTHERS - EPDC

Quantity Survey

**Royal Commission / MSC Review and Approval Status**

- |  |   |
|--|---|
| <input type="checkbox"/> (A) Work May Proceed                              | <input type="checkbox"/> Re-submit not required Incorporate comment and proceed                           |
| <input checked="" type="checkbox"/> (B) Work May Proceed - Minor Comment ✓ | <input checked="" type="checkbox"/> Re-submit not required Incorporate comment Don't proceed              |
| <input type="checkbox"/> (C) Work May Proceed Except as Noted              | <input type="checkbox"/> Submittal incomplete, Complete & Re-submit again                                 |
| <input type="checkbox"/> (D) Disapproved                                   | <input type="checkbox"/> Submittal inconsistent with contract   |
| <input type="checkbox"/> Acceptable with no comment                        | <b>ATTACHMENT :</b>   |
| <input type="checkbox"/> Acceptable with minor comment                     | <input checked="" type="checkbox"/> Engineering Review Comment Sheet (s)                                  |
| <input type="checkbox"/> Unacceptable / Rejected                           | <input type="checkbox"/> EWR List of Submitted Materials Indicating the Review status submitted materials |
| <input type="checkbox"/> Other Comment See Below                           | <input type="checkbox"/> Contract Drawing Submittal Sheet(s) indicating status of submitted drawing(s)    |
|  | <input type="checkbox"/> Other Enclosure / Attachments  |

CSG Log # <b>3004-032.1</b>	Review	Date	CSG Supervisor	Date
Receipt Date: <b>24-9-20</b>		<b>30/10/20</b>		

**RC CONSTRUCTION**

The review and approval is conditionally that the submittal is in compliance with the contract documents. This approval shall not be construed as an approval of a change in Contractscope or price. Prompt response shall be made by the Contractor

ADDITIONAL COMMENTS : \* **Approved with Code - B**  
\* **Refer the mark ups inside Submittal**  
\* **Follow the Comments with attached Comment sheet**

Project File No. \_\_\_\_\_  
EWR No. \_\_\_\_\_  
Ref Number **HAI-RCJ-SUB-JCPDI-R-3004-0032.R1**  
CC: RF / Crono \_\_\_\_\_  
For RC/MSN \_\_\_\_\_  
Engr. Konstantinos Aidinis  
RC Authorized Representative  
Date : \_\_\_\_\_  
*\* with comments*



NUMBER: Y02-03-00-06/03  
DATE OF ISSUE: 01/06/1435



## E W R LIST OF SUBMITTED MATERIALS (NOT APPLICABLE TO DRAWINGS)

CONTRACT NO. : JCPDI R-3004

CONTRACT NAME : CONSTRUCTION OF ROAD 3 BETWEEN ROAD 4 AND 12

ITEM NO	DESCRIPTION	REFERENCE TO CONTRACT DOCUMENT	REVIEW STATUS
1	SINGLE CORE CU/TR-XLPE/PVC 8.7/15KV	16407	<u>B</u>
	MEDIUM VOLTAGE CABLES		
	a) 1C x 300mm <sup>2</sup>	/	
	b) 1C x 120mm <sup>2</sup>	/	
2	MULTI-CORE CU/XLPE/PVC 0.6/1KV	16050	<u>B</u>
	LOW VOLTAGE CABLES		
	a) 4C x 50mm <sup>2</sup>	/	
	b) 4C x 10mm <sup>2</sup>	/	
	c) 4C x 16mm <sup>2</sup>	/	
	d) 4C x 25mm <sup>2</sup>	/	
	e) 4C x 35mm <sup>2</sup>	/	
	f) 2C x 10mm <sup>2</sup>	/	
	g) 2C x 6mm <sup>2</sup>	/	
3	SINGLE-CORE CU/PVC/PVC 0.6/1KV	16050	<u>B</u>
	LOW VOLTAGE CABLES		
	a) 1C x 6mm <sup>2</sup>		
	b) 1C x 10mm <sup>2</sup>		
	c) 1C x 16mm <sup>2</sup>		
	d) 1C x 25mm <sup>2</sup> e) 1C x 50mm <sup>2</sup> (P2 Table 2.07.05.01)		
4	Plain Soft Drawn Stranded Bare Copper	16450	<u>B</u>
	Grounding Conductor - for use in ductbank		
	where it is not direct contact with earth in		
	accordance with RC standard RC-E-15		
	a) 120mm <sup>2</sup>		
	Manufacturer:		
	RED SEA CABLES COMPANY		
	Tel # 966- 1 2886303		
	Fax # 966-1 2886302		

**REVIEW STATUS**

- A - WORK MAY PROCEED-NO COMMENTS
- B - WORK MAY PROCEED-MINOR COMMENTS
- C - WORK MAY PROCEED EXCEPT AS NOTED (Resubmittal Required)
- D - DISAPPROVED- WORK MAY NOT PROCEED (Resubmittal Required)



*Handwritten signature and date: 02/11/2020*

*Handwritten date: 31/10/2020*

*Handwritten date: 3/11/2020*