

**SUBMITTAL # 0234-00**

Project Title	Dhahiat sumou Development	Date	23-Jan-2017
Contract Title	07 Sales Center Construction Work	Contract No.	
Submittal No.:	SUP-SCCW-ATC -ECG -SUB-0234-00		
Submittal Title:	pre-qualification FOR RED SEA CABLES ( RESCAB )		

We are sending herewith under separate cover the drawings / documents / samples listed below :

ITEM NO.	DWGS. SPECS REQ REF.	DESCRIPTION	TYPE	COPIES
1	HARD COPY & SOFT COPY	pre-qualification FOR RED SEA CABLES ( RESCAB ) (ELECT)	SD	3

TYPE:SD=Shop Drawings,SM=Sample,GT=Guarantee,MD=Manufacturer's Data,CT=Certificates,TT=Test Results,OT=Other

Subcontractor/Supplier/Manufacturer:

We certify that the documents / materials submitted herewith have been reviewed in detail and in strict conformance with the contract drawings and specifications except as otherwise stated.

**Submitted by Contractor**

Name	Tamer Emara	Signature	[Signature]	Date	23-Jan-2017
------	-------------	-----------	-------------	------	-------------

**Received by PM**

Name	Yasser Hassan	Signature	[Signature]	Date	
------	---------------	-----------	-------------	------	--

**Received by Consultant**

Name	Wael Fouad	Signature	[Signature]	Date	
------	------------	-----------	-------------	------	--

First Cycle Distribution :  CIMS  ECG (Original)

**Consultant Review Comments**

*- Refer To Comments in attached All sheet.*  
*Ahmed Hassan*

ECG ENGINEERING CONSULTANTS GROUP  
**APPROVED**  
With Corrections As Noted Do Not Resubmit  
By *[Signature]* Date *31/1/2017*

A. Approved  
 B. Approved As Noted  
 C. AS Noted, Will be Resubmitted  
 D. Not Required  
 E. Not Approved

**Submittal Sign Off Consultant**

Name	Wael Fouad	Signature	[Signature]	Date	31/1/2017
------	------------	-----------	-------------	------	-----------

**Approved by PM**

Name	Yasser Hassan	Signature		Date	
------	---------------	-----------	--	------	--

**Approved by Client (When Necessary)**


Name	Hani Abu Khadija	Signature		Date	
------	------------------	-----------	--	------	--

**Received by Contactor**

Name	Tamer Emara	Signature		Date	
------	-------------	-----------	--	------	--

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the contract. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

Second Cycle Distribution :  CIMS (Original)  ECG  ATC



Eng. M. S  
Page 1 of 1  
W.F 25/1/2017

**Date:** 31 / 1 / 2017  
**Project:** Dhahiat Sumou Development (block5 .phase1, package B and mockup)  
**Subject:** ATC – SUBMITTAL SD # 0234 (Prequalification for Red Sea Cables) (RESCAB)  
**Reference:**

---

**Action Code (B).**

**Approved as Noted to the following reasons:-**

- This submittal can be approved only for low voltage cables and wires.
- The contractor shall submit compliance statement refer to project specification.
- The contractor shall arrange factory visit for RESCAB factory.
- After final approval, the contractor can submit material submittal for RESCAB cables for low voltage project cables.

Eng. Ahmed Hassan

ECG ENGINEERING CONSULTANTS GROUP  
**APPROVED**  
With Corrections As Noted Do Not Resubmit  
By  Date 31/1/2017