



# REPORT OF PERFORMANCE


TIC 1450-12

<b>OBJECT</b>	Single-core Power Cable
<b>TYPE</b>	0,6/1 kV, 1x630 mm <sup>2</sup> , Cu/XLPE/PVC
<b>MANUFACTURER</b>	Red Sea Cables Company (RESCAB), Yanbu, Kingdom of Saudi Arabia
<b>CLIENT</b>	Red Sea Cables Company (RESCAB), Yanbu, Kingdom of Saudi Arabia
<b>TESTED BY</b>	KEMA HIGH-VOLTAGE LABORATORY Arnhem, The Netherlands
<b>DATE OF TESTS</b>	4 April until 1 June 2012
<b>TEST PROGRAMME</b>	Type tests in accordance with IEC 60502-1 Edition 2.1 2009-11
<b>SUMMARY AND CONCLUSION</b>	The test object passed the tests.

This Report of Performance applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This report consists of 21 pages in total.

© Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.  
  
S.A.M. Verhoeven  
Director Testing, Inspections &  
Certification The Netherlands

Arnhem, 17 July 2012